

LOCATION 1707 FAIRFIELD DR CITY GASTONIA

BETWEEN Dartmouth STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED <i>Tie over</i>	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>C&W Plastic</u>	<u>66'</u> <u>38'</u>	<u>6/18/94</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1707 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION South side of 1707


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By DT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1992

DEPTH: 3 Ft. In. LOCATION EAST side of FAIRFIELD DR.

"A" P/S READING 1.20 TOTAL ANODES 1* 0 17* 0 L.R. #

REMARKS: 66' of ex 3/4" C&W ser tied over to new main with 38' of 3/4" Plastic pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.20</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY