

LOCATION 1709 FAIRFIELD DR

CITY GASTONIA

BETWEEN DARTMOUTH

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	C&W	51'	6-25-94		
MAIN TO PROP. LINE			TIED OVER	TO NEW PLASTIC MAIN		
PROP. LINE TO BLDG.	3/4"	PLASTIC	92'	6-25-94		

ENTERS: 1709

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 417' NORTH

OF FAIRFIELD

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K. HAYES

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED 1993

DEPTH: 3

Ft.

In.

LOCATION


16' WEST OF FAIRFIELD DR

"A" P/S READING 1.000

TOTAL ANODES 1# 17#

L.R. #

REMARKS: TRACER WIRE NOT Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	'S'	1.0
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY