

LOCATION 1711 FAIRFIELD DR

CITY GASTONIA

BETWEEN

STREET &amp;

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	63' EXT.	PLASTIC	TIED OVER	WITH 32' NEW	3/4" PLASTIC	
MAIN TO PROP. LINE	3/4	PLASTIC	32'	6-25-94		
PROP. LINE TO BLDG.	3/4	PLASTIC	63'	6-25-94		

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION 542' NORTH

OF FAIRFIELD


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K. Hayes

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 15' WEST OF FAIRFIELD DR.

"A" P/S READING TOTAL ANODES 1\* 17\* L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY