

LOCATION 1713 Fair Field Dr. CITY Pastoria  
BETWEEN Hawthorne Dr. STREET & Dartmouth Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	116'	8-31-01		
MAIN TO PROP LINE	5/8"	P	40'	"		
PROP LINE TO BLDG	5/8"	P	76'	"		

ENTERS 1713 BRANCHED INTO 0  
TAP SIZE 1/2" PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W C LOCATION 638' north


PRESSURE TEST @ 100 PSI FOR 1 1/4" HRS BY D. Woody  
of center of Fair Field & Dartmouth Dr.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH 3' FT 0" IN LOCATION 17' west of center of Fair Field Dr.

"A" P/S READING N/A TOTAL ANODES 1# 8 17# 0 LR # 00662490

REMARKS New 5/8" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	nickel