

LOCATION 1723 Fairfield Dr CITY Dartmouth
BETWEEN Southwold STREET & Dartmouth STREET

	SIZE	TYPE	P	LENGTH	S	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	1	39	66		Red over 6-24-94		
MAIN TO PROP. LINE	3/4		39	6				
PROP. LINE TO BLDG.	3/4		0	60				

ENTERS: 1723 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Wade House

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bonett


MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 21' S of Capet

"A" P/S READING 1010 TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: TOTAL 105 Amp Dresser was bonded

**Bare Main Replacement
Program**



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY