

LOCATION 1802 Fairfield Dr. CITY Los Angeles
BETWEEN Hawthorne STREET & Fairfield Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>111</u>	<u>Tied over</u> <u>6-25-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>53</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>58</u>			

ENTERS: 1802 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Exide of house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Amett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 27' E of C of Hawthorne

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: ~~Old~~ **Mahr Replacement Program**



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY