

LOCATION 1807 & 1815 FAirField Dr. Split Services CITY GAstonia
BETWEEN Edgemont Ave STREET & FAirField Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>30'</u>	<u>6-18-94</u>	<u>Tied over 147' Existing 3/4</u>	
MAIN TO PROP. LINE					<u>On 1815</u>	<u>Tied over 186'</u>
PROP. LINE TO BLDG.					<u>Existing 3/4 On 1807</u>	

ENTERS: 1807 FAirField Dr. BRANCHED INTO: 1815 FAirField Dr.
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 336' E of Co of Edgemont Ave

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 15' S of Co of FAirField Dr.

"A" P/S READING PLASTIC TOTAL ANODES 1* L 17* _____ L.R. # _____

REMARKS:

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1807 Riser 1815
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY

7 .85
1815 .85