

LOCATION 2518 Fairgreen DR CITY GASTONIA

BETWEEN Rosehauer DR STREET & Frambrook DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>	<u>8-19-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS: 2518 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 55' N. of center of Rosehauer DR.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler

MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 11' W. of center of Fairgreen DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 452098

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>		
P/S Pipeline Lead - White Existing Main	<u>E</u>		

