

LOCATION 2626 Fairgreen Dr. CITY Gastonia
BETWEEN Beaty Rd. STREET & Union Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	117'	6-27-01		
MAIN TO PROP LINE	3/4"	P	32'	"		
PROP LINE TO BLDG	3/4"	P	85'	"		

ENTERS 2626 BRANCHED INTO 0
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 491' North
of center of Beaty Rd.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3' FT 0" IN LOCATION 14' West of center of Fairgreen Dr.

"A" P/S READING 111.7 TOTAL ANODES 1# 0 17# 0 LR # 10471171

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>rise</u>