

LOCATION 2629 FAIRGREEN DR. CITY CASTONIA

BETWEEN Beatty Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>116'</u>	<u>8-15-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>106'</u>			

ENTERS: 2629 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 506' W. of center of

Beatty Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFSTETTER

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 13' W. of center of FAIRGREEN DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 458110

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY