

LOCATION 310 Fairview Dr.

CITY Gastonia

BETWEEN Hermon

STREET &amp;

Liberty

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	123'	4-7-94		
MAIN TO PROP. LINE	3/4	P	20'			
PROP. LINE TO BLDG.	3/4	P	103'			

ENTERS: 310 Fairview Dr.

BRANCHED INTO: 0

TAP SIZE: 3/8

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 87' E of Cor Hermon St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1968

DEPTH: 3 Ft. 6 In.


LOCATION 13' S of Cor Fairview Dr.

"A" P/S READING .90

TOTAL ANODES 1# 0 17# 0

L.R. #

REMARKS: Existing 2" CW MAIN Comes OFF FARM TAP 15 lbs. Pressure on Main #



## Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	