

LOCATION 2822 Fairview Dr. CITY AUSTONIA
 BETWEEN Jenkins Dairy Rd. STREET & Dallas Pressure City Highway STREET

Service

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	114'	11-14-02		
MAIN TO PROP LINE	5/8"	P	16'	"		
PROP LINE TO BLDG	5/8"	P	98'	"		


ENTERS 2822 BRANCHED INTO 2808-(2900)
 TAP SIZE 5/8" PRESSURE 60 PSI _____ INCHES W C LOCATION 652' West

Service

of cante of Jenkins Dairy Rd.
 PRESSURE-TEST @ 100 PSI FOR 1/4 HRS BY D. Woods
 MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1987
 DEPTH 2' FT 0" IN LOCATION 192' north of cante of Fairview Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 334028

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	service