

LOCATION 3470 Fairview DrCITY GastoniaBETWEEN Stiles

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>122'</u>	<u>7-15-96</u>	<u>Relocated</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 3470 Fairview DrBRANCHED INTO: 3468 Fairview DrTAP SIZE: 3/4PRESSURE 60

PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY S.C.MAIN SIZE 3/4

C.I. _____

BARE STEEL _____

COATED STEEL ☒

PLASTIC _____

YEAR INSTALLED _____

DEPTH: 2

FT.

0


IN.

LOCATION

"A" P/S READING .85TOTAL ANODES 1# 117# 0

L.R. # _____

REMARKS:

Relocated 3/4 Service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY