

LOCATION 201 Fairway Ln. CITY Canton, MA
BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	44'	11-19-02		
MAIN TO PROP LINE	5/8"	P	4'	"		
PROP LINE TO BLDG	5/8"	P	40	"		

ENTERS 201 BRANCHED INTO 0

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 271' west

of catc of fairway Ln.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 15' south of catc of fairway Ln.

"A" P/S READING 714 TOTAL ANODES 1# 8 17# 0 LR # 334022

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	service