

LOCATION 216 Fairway Dr.

CITY GASTONIA

BETWEEN Cedar

STREET & Shepherd St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>87'</u>	<u>4-12-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>17'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>70'</u>			

ENTERS: 216

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 78' N of Cor of Cedar St.


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 14' W of Cor of Fairway Dr.

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY