

LOCATION 659 Falcon Nest Ct. CITY GASTON, NC

BETWEEN Hawk Ridge Dr STREET & Cut-de-Sk STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>35'</u>	<u>6-17-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>25'</u>			

ENTERS: 659 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 610' W. of center of

Hawk Ridge Dr


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY S. HICKS

MAIN-SIZE 3/4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 2 FT 0 IN LOCATION 54' N. of center of Falcon Nest Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 435841

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY