

LOCATION 660 Falcons Nest CITY Gastonia

BETWEEN Osprey Ct STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56'</u>	<u>7-6-98</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>1"</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>11</u>	<u>1"</u>	<u>50'</u>			

ENTERS: 660 BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 317' W of C of

Osprey Ct


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BC

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT IN LOCATION 44' N of C of Falcons Nest

"A" P/S READING plastic TOTAL ANODES 1# ✓ 17# - L.R. # 496652

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY