

LOCATION 518 N Falls St. CITY GASTONIA  
BETWEEN Granite Ave STREET & W. Lincoln St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>98'</u>		<u>5-31-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>78'</u>			

ENTERS: 518 N. Falls St BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 50' NORTH from @ of Granite Ave

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ML  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1994  
DEPTH: 3 FT. 0 IN. LOCATION West side of Falls St.

"A" P/S READING P. TOTAL ANODES 1# 17# L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		