

LOCATION

520 N. Falls St.

CITY

GASTONIA

BETWEEN

Granite Ave

STREET &amp;

W. Lincoln Ave

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	50'		6-19-96	
MAIN TO PROP. LINE	"	"	18'			
PROP. LINE TO BLDG.	"	"	32'			

ENTERS:

SAME

BRANCHED INTO:

TAP SIZE:

3/4"

PRESSURE

60

PSI

INCHES W.C.

LOCATION

87' North from @ of  
Granite Ave.

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS.

BY

mf

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1996

DEPTH:

3 FT.

0 IN.

LOCATION

West Side of Falls Ave

"A" P/S READING


P

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

S

P/S Pipeline Lead - White  
Existing Main

E

ENG. DEPT. USE ONLY