

LOCATION 711 N - Falls St. CITY Gast.

BETWEEN HARRISON St STREET & W. Bradley St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>44'</u>		<u>9-9-96</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>37'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 43' South from @ of Allison Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY mf

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION West side of N. Falls St.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>		
P/S Pipeline Lead - White Existing Main	<u>E</u>		

