

LOCATION 715 N. Falls St. CITY Canton
BETWEEN Allison St. STREET & Harrison St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>6'</u>			<u>7-10-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>4'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 40 PSI _____ INCHES W.C. LOCATION 73' West from Center of Falls St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ml
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P. TOTAL ANODES 1# 17# L.R. # _____

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY