

LOCATION 717 N. Falls St. CITY Gast.
BETWEEN Allison St. STREET & W. Davidson Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>29'</u>			<u>12-10-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>22'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 53' from @ of Allison St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN. LOCATION West Side of Falls Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		