

LOCATION

4315 S. FALLS St

CITY

GASTON

BETWEEN

Kickapoo

STREET &

Stage Coach Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	08'	Relocated 4-25-94		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

4315

BRANCHED INTO: 0

TAP SIZE:

3/4" sec.

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @

100 psi

For

1 1/4 Hrs.

By

[Signature]

MAIN SIZE

3/4

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1978

DEPTH:

1 Ft.

6 In.

LOCATION

"A" P/S READING

P


TOTAL ANODES

1#

17#

L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY