

LOCATION 4319 S. Falls St CITY Los Angeles

BETWEEN Old York Rd STREET & Kickapoo STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>83</u>	<u>7-22-94</u>		
MAIN TO PROP. LINE	<u>5/4</u>	<u>"</u>	<u>20</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>63</u>			

ENTERS: 4319 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side House


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1962

DEPTH: 2 Ft. 6 In. LOCATION 5' E of 1st

"A" P/S READING 180 TOTAL ANODES 1* _____ 17* 1 L.R. # 00299800

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY