

LOCATION 4401 S. FALLS ST CITY Easton, Pa
BETWEEN Second STREET & Reed Ave STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------|------------|-----------|-------------------------------------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>67'</u> | | <input checked="" type="checkbox"/> | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>P</u> | <u>0'</u> | | <u>9-26-97</u> | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>P</u> | <u>67'</u> | | | |

ENTERS: 4401 BRANCHED INTO: 0

TAP SIZE: 3/4 sec. PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY CD

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN. LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: _____



| Test Station | | |
|--|----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Plastic</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY