

LOCATION 4305 Farmbrook DR CITY GATHERN

BETWEEN Woodbridge DR STREET & Cove Creek STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	76'	8-1-96		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	66'			

ENTERS: 4305 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 124' E. of center of Cove Creek


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffsteth

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 15' N. of center of Farmbrook DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 403587

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY