

LOCATION 4401 Farmbrook DR CITY Gastonia

BETWEEN Cove Creek Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	96'	8-1-96		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	86'			

ENTERS: 4401 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 78' W. of center of Cove Creek Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstutler

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 15' N. of center of Farmbrook Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 403652

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		