

LOCATION 4410 Frambrook Dr. CITY GASTON, VA

BETWEEN Cove Creek Dr. STREET & Derry Down Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>118'</u>	<u>8-2-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>83'</u>			

ENTERS: 4410 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI            INCHES W.C. LOCATION 380' SW. of center of

Cove Creek Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler

MAIN-SIZE 2" C.I.            BARE STEEL            COATED STEEL            PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: FT. IN. LOCATION 13' NW. of center of Frambrook Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 403585

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY