

LOCATION 4509 Farmbrook Rd. CITY Gastonia
BETWEEN Derrydown Ln. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>97'</u>	<u>9-8-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>7'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>90'</u>			

ENTERS Same BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 13' North of

Farmbrook Rd & 200' West of Derrydown Ln.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1989

DEPTH 3 FT 6 IN LOCATION 13' North of Farmbrook Ln.

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - I.R. # 00824909

REMARKS
New Service.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Rizer</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

