

LOCATION 1713 FARM POND CT. CITY Wassonville
 BETWEEN Windy Rush LN STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>3-19-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>75'</u>			

ENTERS 1713 BRANCHED INTO
 TAP SIZE 1/2" PRESSURE _____ PSI _____ INCHES W.C. LOCATION 34' N. of C of

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Farm Pond

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1977

DEPTH 3 FT 0 IN LOCATION _____

A P/S READING 1.10 TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS

