

LOCATION 102 Farmview Ave.

CITY Gastonia

BETWEEN Farmview

STREET & Johnston

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	97'	5-5-95	5-5-95	5-5-95
MAIN TO PROP. LINE	3/4	P	35'		250' (3/4" cfm)	
PROP. LINE TO BLDG.	3/4	P	62'		1960	

ENTERS: 102

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION 71' SE OF

Farmview

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M. Parker

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In.


LOCATION 12' SW OF Farmview

"A" P/S READING P

TOTAL ANODES 1* _____ 17* _____

L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	R-riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY