

LOCATION 441 Fawnbrook Ln. CITY Gastonia
BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>P</u>	<u>62'</u>	<u>9-19-02</u>		
MAIN TO PROP LINE	<u>5/8</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>5/8</u>	<u>P</u>	<u>52'</u>			

ENTERS _____ BRANCHED INTO _____
TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 20' W. of Fawnbrook

106 S. of Stagbuck Dr.
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GR

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2002

DEPTH 3 FT 6 IN LOCATION 20' W. of Fawnbrook Ln.

"A" P/S READING N/A TOTAL ANODES 1# — 17# — LR # —

REMARKS Ran New Service.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.250V</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

