

LOCATION 5205 Featherstone Ct CITY Gastonia  
BETWEEN Cramer Woods Dr. STREET & Old Town Ln. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>118'</u>	<u>12-18-2000</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>46'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>72'</u>	<u>"</u>		

ENTERS 5205 Featherstone Ct BRANCHED INTO ⊕  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 220' East of center of Cramer Woods Dr.

PRESSURE TEST @ 160 PSI FOR 1/4 HRS BY D.W.  
MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1999  
DEPTH 3' FT 0" IN LOCATION 17' south of center of Featherstone Ct.

"A" P/S READING N/A TOTAL ANODES 1# ⊕ 17# ⊕ LR # 1178882

REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>