

LOCATION 5209 Featherstone Dr CITY Castroville
BETWEEN Cramer Woods Dr STREET & Cal-de-Sa STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	43'	9.11.00		
MAIN TO PROP LINE	3/4"	P	20'			
PROP LINE TO BLDG	3/4"	P	23'			

ENTERS 5209 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W/C LOCATION 72' E. of center of Featherstone Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000
DEPTH 5 FT 0 IN LOCATION 321' S. of center of Cramer Woods Dr.

"A" P/S READING P TOTAL ANODES I# 0 17#0 LR # 803738

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead White Existing Main	E	