

LOCATION 1272 Fenwick Hall CITY Easton, IA
BETWEEN Plantation Trl STREET & 1288 Fenwick Hall STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>136'</u> | <u>7-27-94</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>Plastic</u> | <u>45'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>91'</u> | | | |

ENTERS: 1272 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 305' E of C of Plantation Trl


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 18' S of C of Fenwick Hall

"A" P/S READING Plastic TOTAL ANODES 1* _____ 17* _____ L.R. # 322631

REMARKS: New 3/4 Plastic Service, with Road Bore



| Test Station | | |
|--|----------|----------------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Riser Plastic</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY