

LOCATION 1280 Fenwick Hall CITY Gastonia

BETWEEN Plantation trl STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	115'	3-24-94		
MAIN TO PROP. LINE	11	11	40			
PROP. LINE TO BLDG.	11	11	75'			

ENTERS: 1280 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION N. side of 1280


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By BC

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 19' E of C of Fenwick

"A" P/S READING Plastic TOTAL ANODES 1* - 17* - L.R. # 118200

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY