

LOCATION 3472 FIELDSTONE CT CITY CHICAGO  
 BETWEEN ROCK CREEK CT STREET & END OF ROAD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>2 1/4"</u>	<u>PLASTIC</u>	<u>182'</u>	<u>8-14-90</u>		
MAIN TO PROP LINE	<u>2 1/4"</u>	<u>PLASTIC</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>2 1/4"</u>	<u>PLASTIC</u>	<u>167'</u>			

ENTERS 3472 FIELDSTONE CT BRANCHED INTO Ø  
 TAP SIZE 2 1/4" PRESSURE 100 PSI INCHES W.C. LOCATION 42' E. OF C. OF FIELDSTONE CT

PRESSURE TEST @ 100 PSI FOR 24 HRS BY RC  
 MAIN SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1994  
 DEPTH 3 FT 6 IN LOCATION 4" NW. OF C. OF ROCK CREEK CT

"A" P/S READING 1/2 PLASTIC TOTAL ANODES 1#        17#        LR #       

REMARKS  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC RISE</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

