

LOCATION 3473 FIELDSTONE DR. CITY GASTONIA
BETWEEN ROCK CREEK CT STREET & CUL DE SAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>126'</u>	<u>10-3-01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>39'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>87'</u>			

ENTERS 3473

BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES WC LOCATION N. side of 3473


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY CK

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC 1 YEAR INSTALLED 2000

DEPTH 3 FT IN LOCATION E. side of FIELDSTONE

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	