

LOCATION 3497 Fieldstone CITY Gastonia

BETWEEN Rock Creek CT STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>105'</u>	<u>8-15-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>80'</u>			

ENTERS 3497 BRANCHED INTO

TAP SIZE 3/4" PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 104' NE. of center of Rock Creek CT


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S/L

MAIN SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 30' SE. of center of Fieldstone DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 230229

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	