

LOCATION 3531 Fieldstone Dr. CITY Gastonia
BETWEEN Misty Ridge ct. STREET & Rock Creek ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>120'</u>	<u>5-11-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>44'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>76'</u>	<u>"</u>		

ENTERS 3531 BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 121' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woods
@ center of Misty Ridge ct.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3' FT 0" IN LOCATION 20' south of center of Fieldstone Dr.

"A" P/S READING 11A TOTAL ANODES 1# Ø 17# Ø LR # 50129616

REMARKS New 3/4" Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u> <u>rise</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	