

LOCATION 3555 Fieldstone DR. CITY Gastonia

BETWEEN Kendrick Rd. STREET & Misty Ridge Cr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	154'	6-7-00		
MAIN TO PROP LINE	3/4"	P	45'			
PROP LINE TO BLDG	3/4"	P	109'			

ENTERS 3555 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 135' S. of center of Misty Ridge Cr.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.M.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 19' SE. of center of Fieldstone DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 486895

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	