

LOCATION 3563 Fieldstone Dr. CITY Gastonia
 BETWEEN Misty Ridge Ct. STREET & Hendrick Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>134'</u>	<u>5-11-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>44'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>90'</u>	<u>"</u>		

ENTERS 3563 BRANCHED INTO

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W/C LOCATION 177' West


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY center of misty Ridge ct.
D. Woody

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 2' FT 10" IN LOCATION 20' south of center of Fieldstone Dr.

"A" P/S READING N/A TOTAL ANODES 1# 17# LR # 0366669

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic service</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	