

LOCATION 3578 Fieldstone Dr. CITY CANTONIA
 BETWEEN Murly Ridge STREET A Kendrick Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>112'</u>	<u>9-15-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>8'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>104'</u>			

ENTERS 3578 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 172' W of Cap Kendrick Rd.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RLC

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 6 IN LOCATION 21' S of Cap Fieldstone Dr.

"A" P/S READING Plastic N/A TOTAL ANODES I# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>Plastic</u>