

LOCATION 207 E. 5th CITY San Francisco  
BETWEEN Oakland STREET & Union St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>49'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			<u>11-21-96</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>44</u>			

ENTERS: 207 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY EP

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING Plastic TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		