

LOCATION 209 E. 5th AVE CITY Georgetown
BETWEEN BROAD STREET & UNION Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>53</u>			<u>9-5-86</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>13</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>40</u>			

ENTERS: 209 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE 100 P.S.I. _____ INCHES W.C. LOCATION S. Side 5th AVE


PRESSURE TEST: @ 100 psi For 14 Hrs. By ~~Elmore~~ Elmore

MAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL — PLASTIC X YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. # —

REMARKS: Tied into new 4" Plastic main 1-25-94



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY