

LOCATION 221 E. 5th

CITY ConoverBETWEEN 13 Road

STREET &

Union Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	3'	2-2-54	Tied over	36' 0" EXT
MAIN TO PROP. LINE					3/4" gal to 4" plastic	
PROP. LINE TO BLDG.					main	

ENTERS: 221

BRANCHED INTO: 219 & 223

TAP SIZE:

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi

For 4 Hrs.

By RF

MAIN-SIZE 4"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1983

DEPTH:

4 Ft. 0 In.

LOCATION

"A" P/S READING

TOTAL ANODES 1*

017* 0


L.R. #

REMARKS:

P.S. Reading on #219 - 1.2 Riser

P.S. Reading on #223 - 1.2 Riser

Tiger wire tied RA at main



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S Riser	1.2
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY

* NOTE: 219 E. FIFTH IS AN
ISOLATED SERVICE
SEE C.P. # 88888