

LOCATION 407 E 5<sup>th</sup>

CITY GASTONIA

BETWEEN Columbia

STREET &amp; W. How

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	C&W	35'	8-7-93	Transition	Fitting
MAIN TO PROP. LINE					used to tie over 35'	
PROP. LINE TO BLDG.					C&W to plastic MAIN	

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 28' West of Columbia ST


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R. Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 14 South of E. 5<sup>th</sup> ST.

"A" P/S READING 4 C&W TOTAL ANODES 1# 1 17# L.R. #

REMARKS: Tracer wire Not Bonded to main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	8.5
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY