

LOCATION 415 E. 5th Ave. CITY GASTONIA  
BETWEEN OAK St. STREET & Columbia St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>7/31/93</u>	<u>Tie over</u>	<u>71' Existing</u>
MAIN TO PROP. LINE					<u>3/4 PLASTIC to new</u>	
PROP. LINE TO BLDG.					<u>Main</u>	


ENTERS: 415 E. 5th BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 118' W of Cor of OAK St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL  
MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1993  
DEPTH: 3 Ft. 0 In. LOCATION 17' S of Cor of E. 5th ave.

"A" P/S READING P TOTAL ANODES 1\* — 17\* — L.R. # —

REMARKS:

- Bare Main Renewal - Tie over's



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY