

LOCATION 507 E. 5th CITY Bastonia
BETWEEN OAK STREET & Avon STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>1'</u>	<u>8-14-93</u>	<u>Tied over</u>	<u>92' of EXT</u>
MAIN TO PROP. LINE					<u>3/4 plastic to</u>	<u>EXT. 2" plastic</u>
PROP. LINE TO BLDG.					<u>main</u>	

ENTERS: 507 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 13' 50' cot 5th
33' cot of Avon

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1* — 17* — L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY