

LOCATION 201 W Fifth AveCITY GASTONIABETWEEN South st

STREET &

NEIL

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	29'	10/9/95		
MAIN TO PROP. LINE	3/4"		10'			
PROP. LINE TO BLDG.	3/4"		19'			

ENTERS: 201

BRANCHED INTO:


TAP SIZE: 1/2"PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION East side of 201PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1991DEPTH: 3 Ft. 0 In. LOCATION West side of South st"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # 508001

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY